



by



UL723 (ASTM E-84) Surface Burning Characteristics

Customer: Jain (Americas) Inc.
Project Number: 07CA56359

Data Summary

Test No.	Test Code	Sample Description	FSI Flame Spread Index	SDI Smoke Developed Index
1	12030712	PVC Sheeting material - 3mm.	15	450
2	12030713	PVC Sheeting material - 6mm.	15	Over 500
3	12030714	PVC Sheeting material 10mm.	15	Over 500
4	12030715	PVC Sheeting material 12.7mm.	15	Over 500
5	12030716	PVC Sheeting material 16mm.	15	Over 500
6	12030717	PVC Sheeting material 19mm.	20	Over 500
7	12030718	PVC Sheeting material 25mm.	20	Over 500

